



Las Vegas Fire & Rescue Fire Prevention Division Information Sheet



Effective Date: February 1, 2011

CLV Ordinance #6124

The items listed are basic information only. Codes are subject to change. Additional requirements may apply.

Liquefied Petroleum Gases

A special use permit shall be obtained in accordance with The City of Las Vegas Municipal Code 19.04.050(B) for Liquefied Petroleum Gas container with an aggregate water capacity exceeding 288 gallons. **SNFC 105.7.10**

An operational permit is required for storage and use of LP-gas except for individual containers with a 500-gallon water capacity of less serving occupancies in Group R-3. **IFC 105.6.27**

Portable LP-gas containers are allowed to be used temporarily for demonstrations and public exhibitions. Such containers shall not exceed a water capacity of 12 pounds. Where more than one such container is present in the same room, each container shall be separated from other containers by a distance of not less than 20 feet. **IFC 3803.2.1.5**

“No Smoking” signs shall be posted when required by the fire code official. Smoking within 25 feet of a point of transfer, while filling operations are in progress at LP-gas containers or vehicles, shall be prohibited. **IFC 3807.2**

Where exposed to vehicular damage due to proximity to alleys, driveways or parking areas, LP-gas containers, regulators and piping shall be protected in accordance with the *International Fire Code* Section 312 (Vehicle Impact Protection) **IFC 3807.4**

Empty LP-gas containers that have been in LP-gas service shall be considered as full containers for the purpose of determining the maximum quantities of LP-gas allowed. **IFC 3809.5**

Las Vegas Fire & Rescue
Fire Prevention Division
(702)229-0366
www.lasvegasnevada.gov/LawsCodes/fire_code.asp