



## DUCT / AREA DETECTOR TEST DATA

DATE: \_\_\_\_\_

CONTRACTOR NAME: \_\_\_\_\_

PERMIT # \_\_\_\_\_ APPLICATION # \_\_\_\_\_

JOB NAME & ADDRESS: \_\_\_\_\_

TESTING EQUIPMENT TYPE: \_\_\_\_\_

Devices upon detection of smoke shall automatically shutoff air-moving equipment by interrupting the power source.

DUCT DETECTORS                      AREA DETECTORS                      (circle one)

NUMBER OF DEVICES: \_\_\_\_\_

### DUCT DETECTORS

MANUFACTURER'S AIRFLOW REQUIREMENTS:

(fpm min.) \_\_\_\_\_ (fpm max.) \_\_\_\_\_

(water column min.) \_\_\_\_\_ (water column max.) \_\_\_\_\_

HVAC EQUIPMENT AIRFLOW OUTPUT IN CFM \_\_\_\_\_

EQUIPMENT SHUTOFF ACCOMPLISHED WHEN DEVICE PUT INTO ALARM:

YES: \_\_\_\_\_ NO: \_\_\_\_\_

PERSON PERFORMING TEST: \_\_\_\_\_

TITLE & AFFILIATION: \_\_\_\_\_